



SUPREME TEST HOUSE

Address: B-9, 2nd Floor, Sector 64, Noida, 201301

Mobile: +91-82658 94049 | +91-95993 42128

Website: www.supremetesthouse.com

Email: info@supremetesthouse.com

An ISO 9001:2015, ISO 14001:2015, ISO 45001:2018 Certified Laboratory



NABL ACCREDITED LABORATORY

TEST REPORT

Sample Name: Drinking water	Report No: STH/2025/03/08/01
Customer Name: DUV International School	Sample Quantity: 1 Ltr
Customer Address: Radha Kunj Colony, Sector-123, Noida.	Sample Condition : Good Temperature: 25°C±2 Humidity : 55%±10
ULR No.: TC14633025030801F	Ref. No.: Nil.
Sample Collected By: Mintu Kumar (From Lab)	
Sample Received On: 08/03/2025	Duration of Testing: 08/03/2025-12/03/2025
Tested Location : At Laboratory	Reporting Date : 12/03/2025

S.No.	Test Parameter	Test Result	Requirement as per IS:10500:2012, Acceptable/Permissible Limit in the absence of alternate source	Test Method
Chemical Parameters				
1.)	Color, Hazen units	2	5/15	IS: 3025-(P-4)
2.)	Odour	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-5)
3.)	pH @27°C	7.11	6.5-8.5/No relaxation	IS: 3025-(P-11)
4.)	Taste	Agreeable	Agreeable/ Agreeable	IS: 3025-(P-8)
5.)	Turbidity (NTU), Max.	<1	1/5	IS: 3025-(P-10)
6.)	T.D.S (mg/l), Max.	68	500/2000	IS: 3025-(P-16)
7.)	Total hardness (mg/l), Max.	52	200/600	IS: 3025-(P-21)
8.)	Chloride (mg/l), Max	17.5	250/1000	IS: 3025-(P-32)
9.)	Residual free chlorine (mg/l) ,Max	0.02	0.2/1	IS: 3025-(P-26)
10.)	Iron (mg/l) ,Max	0.008	1.0/No Relaxation	IS: 3025-(P-53)
11.)	Fluoride (mg/l) ,Max	0.010	1.0/1.5	IS: 3025-(P-60)
12.)	E.Coli Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS: 1622-1981
13.)	Total Coliform Bacteria	Not detected	Shall not be detectable in any 100ml Sample	IS: 1622-1981

End of Report

Page 1 of 1



Verified By (For Supreme Test House)

Aran Kumar
(Quality Manager)



Authorised signatory
Pradeep Bhardwaj
(Technical Manager)

Note: (1) The report refers only to the particular sample(s) submitted for testing. (2) This report shall not to be reproduced except in full without approval of the laboratory or in part and cannot be evidence in the court of Law. (3) Any discrepancy observed in the test report shall be brought in to the notice of the laboratory within week. (4) Results applied to the sample as received in the laboratory submitted by customer